

Viva Energy Australia Pty Ltd

Parramatta Terminal: Gate 4 Durham Street, Rosehill NSW 2142

Environment Protection License (EPL) 660

Licensee: Viva Energy Australia Pty Ltd EPL No.: 660								
Monitoring Point EPA ID no. 1 (Jordan VRU)* Monitoring Frequency: Annually between October and January Pollutant monitored: Organic Vapours mg/L (milligrams per litre) EPL Limit: 110 mg/L								
Location	Date	Start Time	Measurement Period	Measurement Levels (mg/L)	(Potential) Non-compliance/breach	Data obtained Date	Data published Date	Comments
Jordan VRU	15/01/2014	09:27am	240min	5.71	No	-	-	
Jordan VRU	15/01/2015	08:25am	240min	1.14	No	-	-	
Jordan VRU	20/01/2016	12:32pm	241min	0.91	No	-	-	
Jordan VRU	13/04/2017	08:26am	241min	2.66	No	-	-	
Jordan VRU	11/01/2018	08:51am	238min	0.76	No	-	-	
Jordan VRU	10/01/2019	07:40am	220min	0.47	No	-	-	
Jordan VRU	30/01/2020	06:13am	240min	1.50	No	11/03/2020	27/07/2020	

*Jordan VRU is the Vapour Recovery Unit for the Parramatta Terminal Gantry and is located immediately adjacent to the Gantry. Its location is shown within the EPL660 which can be viewed on the NSW EPA website at <https://app.epa.nsw.gov.au/prpoeoapp/default.aspx>

Monitoring Point EPA ID no. 2 (Vapour Emissions Control System (VECS))

Monitoring of this location is not performed as the activity it relates to (truck loading of residual material) is not undertaken. This activity and the associated monitoring requirement is proposed to be removed from the License during the next EPL review.

Correction Log

Viva Energy Australia Pty Ltd

Parramatta Terminal

Environment Protection License 660

Instrument: High Quality Gas Analyser

Pollutant: Unrecovered Organic Vapours

Sample Point	Sample Date and Time	Original Data	Corrected Data	Date Corrected	Date originally published	Reason