

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.2 – Main Interceptor Pumpout					
Pollutant	pH	Phenols	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit	6.0-9.0	0.5	100	50	
Units of Measure		mg/L	mg/L	mg/L	
Frequency as per EPL	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
Aug-14	No discharge				Sep-14
Sep-14	No discharge				Oct-14
Oct-14	No discharge				Dec-14
Nov-14	No discharge				Dec-14
Dec-14	No discharge				Jan-15
Jan-15	No discharge				Feb-15
4/02/2015 16:00	7.7	<0.01	13	32	Mar-15
Mar-15	No discharge				May-15
Apr-15	No discharge				May-15
May-15	No discharge				Jul-15
Jun-15	No discharge				Jul-15
Jul-15	No discharge				Sep-15
Aug-15	No discharge				Sep-15
Sep-15	No discharge				Oct-15
Oct-15	No discharge				Nov-15
Nov-15	No discharge				Dec-15
Dec-15	No discharge				Jan-16
Jan-16	No Discharge*				10-Mar-16
Feb-16	No Discharge				10-Mar-16
Mar-16	No Discharge				26-Apr-16
Apr-16	No Discharge				17/06/2016
May-16	No Discharge				17/06/2016
Jun-16	No Discharge				12/09/2016
Jul-16	No Discharge				12/09/2016
Aug-16	No Discharge				12/09/2016
Sep-16	No Discharge				21/10/2016
Oct-16	No Discharge				16/11/2016
Nov-16	No Discharge				13/01/2017
Dec-16	No Discharge				13/01/2017
Jan-17	No discharge				16/02/2017
Feb-17	No discharge				17/03/2017
Mar-17	No discharge				8/05/2017

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.2 – Main Interceptor Pumpout					
Pollutant	pH	Phenols	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit	6.0-9.0	0.5	100	50	
Units of Measure		mg/L	mg/L	mg/L	
Frequency as per EPL	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
Apr-17		No discharge			8/05/2017
May-17		No discharge			14/06/2017
Jun-17		No discharge			10/07/2017
Jul-17		No discharge			29/08/2017
Aug-17		No discharge			29/08/2017
Sep-17		No discharge			8/11/2017
Oct-17		No discharge			8/11/2017
Nov-17		No discharge			8/02/2018
Dec-17		No discharge			8/02/2018
Jan-18		No discharge			8/02/2018
Feb-18		No discharge			16/03/2018
Mar-18		No discharge			9/05/2018
Apr-18		No discharge			9/05/2018
May-18		No discharge			19/06/2018
Jun-18		No discharge			15/08/2018
Jul-18		No discharge			15/08/2018
Aug-18		No discharge			5/11/2018
Sep-18		No discharge			5/11/2018
Oct-18		No discharge			5/11/2018
Nov-18		No discharge			31/12/2018
Dec-18		No discharge			31/12/2018
Jan-19		No discharge			25/03/2019
Feb-19		No discharge			25/03/2019
Mar-19		No discharge			11/06/2019
Apr-19		No discharge			11/06/2019
May-19		No discharge			11/06/2019
Jun-19		No discharge			19/08/2019
Jul-19		No discharge			19/08/2019
Aug-19		No discharge			23/10/2019
Sep-19		No discharge			23/10/2019
Oct-19		No discharge			11/12/2019
Nov-19		No discharge			11/12/2019

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.2 – Main Interceptor Pumpout					
Pollutant	pH	Phenols	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit	6.0-9.0	0.5	100	50	
Units of Measure		mg/L	mg/L	mg/L	
Frequency as per EPL	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	

NOTE: * this is a correction, data previously advised was ascribed to incorrect discharge point