

Licensee: Viva Energy Australia Pty Ltd

EPL 570

EPA ID No.29 – LBL Interceptor Bay 3 & 4 Overflow

Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit			80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	
22/12/2015	6.9	9.3	62	1/01/2015
4/01/2016*	7.7	9.3	25	18/02/2016
5/01/2016	7.6	2.8	<5	18/02/2016
6/01/2016	7.6	7	15	18/02/2016
15/01/2016	8.4	7.7	13	18/02/2016
30/01/2016**	7.7	5.1	420	10 March 2016 ^(26 April 2016)
31/01/2016**	7.6	4.9	150	10 March 2016 ^(26 April 2016)
01/02/2016**	7.7	5.4	70	10 March 2016 ^(26 April 2016)
March 2016	No discharge			26/04/2016
April 2016	No discharge			17/06/2016
May 2016	No discharge			17/06/2016
5/06/2016	8.1	8.4	86	16/09/2016
7/06/2016	7.7	5.1	78	16/09/2016
8/06/2016	7.6	3.8	39	16/09/2016
24/08/2016	8	4.6	210	16/09/2016
2/09/2016	7.7	3.9	13	21/10/2016
3/09/2016	8	5.8	51	21/10/2016
4/09/2016	7.9	5	22	21/10/2016
October 2016	no discharge			16/11/2016
November 2016	no discharge			13/01/2017
December 2016	no discharge			13/01/2017
January 2017	no discharge			16/02/2017
27/02/2017	7.7	7.3	64	6/04/2017
28/02/2017	7.8	7.7	24	6/04/2017
1/03/2017	7.4	6	140	17/03/2017

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd

EPL 570

EPA ID No.29 – LBL Interceptor Bay 3 & 4 Overflow

Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit			80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	
2/03/2017	8.4	6.1	68	17/03/2017
3/03/2017	7.8	6.4	36	17/03/2017
4/03/2017	7.9	8	50	17/03/2017
5/03/2017	7.9	6.6	49	17/03/2017
18/03/2017	8.1	7.9	20	6/04/2017
19/03/2017	7.9	7.2	15	6/04/2017
20/03/2017	7.9	6.8	<5	6/04/2017
22/03/2017	7.8	7.4	10	6/04/2017
April 2017	no discharge			8/05/2017
May 2017	no discharge			14/06/2017
8/06/2017	7.8	5.3	39	10/07/2017
9/06/2017	7.9	5.8	37	10/07/2017
July 2017	no discharge			29/08/2017
August 2017	no discharge			29/08/2017
September 2017	no discharge			8/11/2017
October 2017	no discharge			8/11/2017
November 2017	no discharge			8/02/2018
December 2017	no discharge			8/02/2018
January 2018	no discharge			8/02/2018
February 2018	no discharge			16/03/2018
March 2018	no discharge			9/05/2018
April 2018	no discharge			9/05/2018
May 2018	no discharge			19/06/2018
June 2018	no discharge			15/08/2018
July 2018	no discharge			15/08/2018

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd				
EPL 570				
EPA ID No.29 – LBL Interceptor Bay 3 & 4 Overflow				
Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit			80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	
August 2018	no discharge			5/11/2018
September 2018	no discharge			5/11/2018
5/10/2018	7.2	5.6	38	5/11/2018
6/10/2018	7.6	6	19	5/11/2018
29/11/2018	7.8	2.7	15	31/12/2018
December 2018	no discharge			31/12/2018

*Note 1: Where more than one sample per day is taken during a discharge, the first sample of each day is reported.

**Note 2: data subject to correction, not originally available for TOC

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.