

Licensee: Viva Energy Australia Pty Ltd

EPL 570

EPA ID No.28 – East Interceptor Bays 1 & 2 Overflow

Pollutant	pH	Oil and Grease	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit				80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
8/01/2016	7.8	<5	4.8	<5	18/02/2016
15/01/2016	8.4	<5	7.7	13	18/02/2016
22/01/2016*	8	<5	6.8	9	1/02/2016
23/01/2016	8	<5	6.7	8	1/02/2016
24/01/2016	7.8	<5	2.9	<5	1/02/2016
26/01/2016	7.3	<5	12	15	18/02/2016
March 2016	No discharge				26/04/2016
April 2016	No discharge				17/06/2016
May 2016	No discharge				17/06/2016
5/06/2016	7	<5	2	5	16/09/2016
19/06/2016	7.6	<5	2.2	20	16/09/2016
21/06/2016	7.4	<5	1.8	15	16/09/2016
20/07/2016	8.1	n/a	2.6	110	16/09/2016
21/07/2016	8.2	n/a	3.4	<5	16/09/2016
23/07/2016	8	n/a	3.4	<5	16/09/2016
3/08/2016	8.3	n/a	3.5	<5	16/09/2016
4/08/2016	8.1	n/a	7.9	23	16/09/2016
5/08/2016	8.1	n/a	3.1	<5	16/09/2016
September 2016	no discharge				21/10/2016
October 2016	no discharge				16/11/2016
November 2016	no discharge				16/02/2017
December 2016	no discharge				16/02/2017
January 2017	no discharge				16/02/2017
February 2017	no discharge				15/03/2017
18/03/2017	8.1	n/a	7.8	17	6/04/2017
19/03/2017	7.5	n/a	3.3	<5	6/04/2017
20/03/2017	7.6	n/a	3.4	<5	6/04/2017

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd

EPL 570

EPA ID No.28 – East Interceptor Bays 1 & 2 Overflow

Pollutant	pH	Oil and Grease	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit				80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
April 2017		no discharge			8/05/2017
May 2017		no discharge			14/06/2017
8/06/2017	7.8	n/a	3.5	6	10/07/2017
9/06/2017	7.5	n/a	3	10	10/07/2017
July 2017		no discharge			29/08/2017
August 2017		no discharge			29/08/2017
September 2017		no discharge			8/11/2017
October 2017		no discharge			8/11/2017
November 2017		no discharge			8/02/2018
December 2017		no discharge			8/02/2018
January 2018		no discharge			8/02/2018
February 2018		no discharge			16/03/2018
March 2018		no discharge			9/05/2018
April 2018		no discharge			9/05/2018
May 2018		no discharge			19/06/2018
June 2018		no discharge			15/08/2018
July 2018		no discharge			15/08/2018
August 2018		no discharge			5/11/2018
September 2018		no discharge			5/11/2018
5/10/2018	7.4	n/a	2	14	5/11/2018
6/10/2018	7.6	n/a	3	9	5/11/2018
7/10/2018	7.6	n/a	2.3	7	5/11/2018
8/10/2018	7.6	n/a	2.4	<5	5/11/2018
10/10/2018	7.5	n/a	2.5	<5	5/11/2018
11/10/2018	7	n/a	2.9	<5	5/11/2018
14/10/2018	7	n/a	2.5	<5	5/11/2018
15/10/2018	7.4	n/a	2.6	<5	5/11/2018

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.28 – East Interceptor Bays 1 & 2 Overflow					
Pollutant	pH	Oil and Grease	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit				80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
21/10/2018	7.5	n/a	7.7	8	5/11/2018
29/11/2018	7.8	n/a	5.8	<5	31/12/2018
30/11/2018	7.9	n/a	2.5	<5	31/12/2018
December 2018	no discharge				31/12/2018
January 2019	no discharge				25/03/2019
February 2019	no discharge				25/03/2019
17/03/2019	8.8	n/a	3.7	10	25/03/2019
18/03/2019	7.8	n/a	5.5	8	25/03/2019
19/03/2019	7.5	n/a	5.9	8	11/06/2019
20/03/2019	7.8	n/a	6.2	31	11/06/2019
Apr-19	no discharge				11/06/2019
May-19	no discharge				11/06/2019
Jun-19	no discharge				19/08/2019
Jul-19	no discharge				19/08/2019
Aug-19	no discharge				23/10/2019
19/09/2019	7.6	n/a	2.2	<5	23/10/2019
Oct-19	no discharge				11/12/2019
Nov-19	no discharge				11/12/2019

Note: Where more than one sample per day is taken during a discharge, the first sample of each day is reported.

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.