

Licensee: Viva Energy Australia Pty Ltd

EPL 570

EPA ID No.29 – East Interceptor Bays 3 & 4 Overflow

Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit			80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	
22/12/2015	6.9	9.3	62	1/01/2015
4/01/2016*	7.7	9.3	25	18/02/2016
5/01/2016	7.6	2.8	<5	18/02/2016
6/01/2016	7.6	7	15	18/02/2016
15/01/2016	8.4	7.7	13	18/02/2016
30/01/2016**	7.7	5.1	420	10 March 2016 ^(26 April 2016)
31/01/2016**	7.6	4.9	150	10 March 2016 ^(26 April 2016)
01/02/2016**	7.7	5.4	70	10 March 2016 ^(26 April 2016)
March 2016	No discharge			26/04/2016
April 2016	No discharge			17/06/2016
May 2016	No discharge			17/06/2016
5/06/2016	8.1	8.4	86	16/09/2016
7/06/2016	7.7	5.1	78	16/09/2016
8/06/2016	7.6	3.8	39	16/09/2016
24/08/2016	8	4.6	210	16/09/2016
2/09/2016	7.7	3.9	13	21/10/2016
3/09/2016	8	5.8	51	21/10/2016
4/09/2016	7.9	5	22	21/10/2016
October 2016	no discharge			16/11/2016
November 2016	no discharge			13/01/2017
December 2016	no discharge			13/01/2017
January 2017	no discharge			16/02/2017
27/02/2017	7.7	7.3	64	6/04/2017
28/02/2017	7.8	7.7	24	6/04/2017
1/03/2017	7.4	6	140	17/03/2017
2/03/2017	8.4	6.1	68	17/03/2017
3/03/2017	7.8	6.4	26	17/03/2017

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd				
EPL 570				
EPA ID No.29 – East Interceptor Bays 3 & 4 Overflow				
Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit			80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	
4/03/2017	7.9	8	50	17/03/2017
5/03/2017	7.9	6.6	49	17/03/2017
18/03/2017	8.1	7.9	20	6/04/2017
19/03/2017	7.9	7.2	15	6/04/2017
20/03/2017	7.9	6.8	<5	6/04/2017
22/03/2017	7.8	7.4	10	6/04/2017
April 2017		no discharge		8/05/2017
May 2017		no discharge		14/06/2017
8/06/2017	7.8	5.3	39	10/07/2017
9/06/2017	7.9	5.8	37	10/07/2017
July 2017		no discharge		29/08/2017
August 2017		no discharge		29/08/2017
September 2017		no discharge		8/11/2017
October 2017		no discharge		8/11/2017
November 2017		no discharge		8/02/2018
December 2017		no discharge		8/02/2018
January 2018		no discharge		8/02/2018
February 2018		no discharge		16/03/2018
March 2018		no discharge		9/05/2018
April 2018		no discharge		9/05/2018
May 2018		no discharge		19/06/2018
June 2018		no discharge		15/08/2018
July 2018		no discharge		15/08/2018
August 2018		no discharge		5/11/2018
September 2018		no discharge		5/11/2018
5/10/2018	7.2	5.6	38	5/11/2018
6/10/2018	7.6	6.1	40	5/11/2018

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd				
EPL 570				
EPA ID No.29 – East Interceptor Bays 3 & 4 Overflow				
Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit			80 (within 48hrs of rain event)	
Units of Measure		mg/L	mg/L	
Frequency	Daily when discharging	Daily when discharging	Daily when discharging	
29/11/2018	7.8	2.7	15	31/12/2018
December 2018		no discharge		31/12/2018
January 2019		no discharge		25/03/2019
February 2019		no discharge		25/03/2019
17/03/2019	7.8	6.2	19	25/03/2019
18/03/2019	7.6	5.6	11	25/03/2019
19/03/2019	7.6	5.8	10	11/06/2019
20/03/2019	7.8	6.1	10	11/06/2019
Apr-19		no discharge		11/06/2019
May-19		no discharge		11/06/2019
Jun-19		no discharge		19/08/2019
Jul-19		no discharge		19/08/2019
Aug-19		no discharge		23/10/2019
19/09/2019	7.4	6.7	13	23/10/2019
Oct-19		no discharge		11/12/2019
Nov-19		no discharge		11/12/2019

*Note 1: Where more than one sample per day is taken during a discharge, the first sample of each day is reported.

**Note 2: data subject to correction, not originally available for TOC

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.