

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.30 – East Interceptor Pumpout					
Pollutant	pH	Oil and Grease	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit	6.0-9.0	10	100	50	
Units of Measure		mg/L	mg/L	mg/L	
Frequency as per EPL	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
1/09/2014*	7.6	<5	5.6	9	Oct-14
2/09/2014*	7.9	<5	5.8	9	
3/09/2014*	7.9	<5	5.6	12	
4/09/2014*	7.8	<5	5.5	5	
6/09/2014*	8.1	<5	4.3	5	
7/09/2014*	8	<5	6.8	8	
8/09/2014*	8	<5	6.1	10	
15/10/2014*	7.2	<5	5.7	43	Dec-14
18/10/2014*	6.8	<5	4.6	37	
Nov-14	No discharge in November				Dec-14
6/12/2014	-	<5	18	-	Jan-15
7/12/2014	6.8	<5	8.3	-	
8/12/2014	-	<5	3.7	-	
11/12/2014	-	<5	7.4	-	
12/12/2014	6.7	<5	4.9	26	
13/12/2014	6.7	<5	5.2	20	
27/01/2015	7.3	<5	7.5	22	Feb-15
28/01/2015	7.2	<5	2	<5	
29/01/2015	7.2	<5	2.2	<5	
30/01/2015	7.3	<5	2.1	<5	
9/02/2015	6.9	<5	5.7	41	Mar-15
Mar-15	No discharge in March				May-15
20/04/2015	7.6	<5	4.5	<5	May-15
21/04/2015	6.8	<5	3.4	15	
22/04/2015	6.9	<5	2.5	47	
23/04/2015	7	<5	6.7	8	
24/04/2015	7.3	<5	3	<5	
25/04/2015	7.6	<5	4.4	<5	
26/04/2015	7.6	<5	5.9	<5	
27/04/2015	7	<5	6.4	<5	
12/05/2015	8	<5	6.2	25	Jul-15
Jun-15	No discharge				Jul-15
Jul-15	No discharge				Sep-15

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.30 – East Interceptor Pumpout					
Pollutant	pH	Oil and Grease	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit	6.0-9.0	10	100	50	
Units of Measure		mg/L	mg/L	mg/L	
Frequency as per EPL	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
Aug-15		No discharge			Sep-15
Sep-15		No discharge			Oct-15
Oct-15		No discharge			Nov-15
Nov-15		No discharge			Dec-15
Dec-15		No discharge			
Jan-16		No discharge			
Feb-16		No discharge			
Mar-16		No discharge			26-Apr-16
Apr-16		No discharge			17/06/2016
May-16		No discharge			17/06/2016
Jun-16		No discharge			16/09/2016
Jul-16		No discharge			16/09/2016
Aug-16		No discharge			16/09/2016
Sep-16		No discharge			21/10/2016
Oct-16		No discharge			16/11/2016
Nov-16		No discharge			13/01/2017
Dec-16		No discharge			13/01/2017
Jan-17		No discharge			16/02/2017
Feb-17		No discharge			15/03/2017
Mar-17		No discharge			8/05/2017
Apr-17		No discharge			8/05/2017
May-17		No discharge			14/06/2017
Jun-17		No discharge			10/07/2017
Jul-17		No discharge			29/08/2017
Aug-17		No discharge			29/08/2017
Sep-17		No discharge			8/11/2017
Oct-17		No discharge			8/11/2017
Nov-17		No discharge			8/02/2018
Dec-17		No discharge			8/02/2018
Jan-18		No discharge			8/02/2018
Feb-18		No discharge			16/03/2018
Mar-18		No discharge			9/05/2018
Apr-18		No discharge			9/05/2018

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
EPL 570					
EPA ID No.30 – East Interceptor Pumpout					
Pollutant	pH	Oil and Grease	Total Organic Carbon	Total Suspended Solids	Publishing Date
Licence Limit	6.0-9.0	10	100	50	
Units of Measure		mg/L	mg/L	mg/L	
Frequency as per EPL	Daily when discharging	Daily when discharging	Daily when discharging	Daily when discharging	
May-18		No discharge			19/06/2018
Jun-18		No discharge			15/08/2018
Jul-18		No discharge			15/08/2018
Aug-18		No discharge			5/11/2018
Sep-18		No discharge			5/11/2018
Oct-18		No discharge			5/11/2018
Nov-18		No discharge			31/12/2018
Dec-18		No discharge			31/12/2018
Jan-19		No discharge			25/03/2019
Feb-19		No discharge			25/03/2019
Mar-19		No discharge			11/06/2019
Apr-19		No discharge			11/06/2019
May-19		No discharge			11/06/2019
Jun-19		No discharge			19/08/2019
Jul-19		No discharge			19/08/2019
Aug-19		No discharge			23/10/2019
Sep-19		No discharge			23/10/2019
Oct-19		No discharge			11/12/2019
Nov-19		No discharge			11/12/2019
Dec-19		No discharge			6/02/2020
Jan-20		No discharge			6/02/2020
Feb-20		No discharge			13/03/2020

*Note 1: Where more than one sample per day is taken during a discharge, the first sample of each day is reported.

**Note 2: data subject to correction, not originally available for TOC

Note: data previously listed for Discharge Point 30, now correctly ascribed to Discharge Points 28 & 29 (from December 2015).