

Licensee: Viva Energy Australia Pty Ltd					
Clyde Terminal: Durham Street, Camellia NSW					
Environment Protection Licence (EPL) 570					
EPA ID No.25 – Flexible discharge outlet					
Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Data obtained Date	Publishing Date
Licence Limit	6.0-9.0	100	50		
Units of Measure		mg/L	mg/L		
Frequency as per EPL	<24 hrs prior to discharge	<24 hrs prior to discharge	<24 hrs prior to discharge		
Jan-16	No discharge				Mar-16
Feb-16	No discharge				Mar-16
Mar-16	No discharge				Apr-16
Apr-16	No discharge				17/06/2016
May-16	No discharge				17/06/2016
Jun-16	No discharge				12/09/2016
Jul-16	No discharge				12/09/2016
Aug-16	No discharge				12/09/2016
Sep-16	No discharge				21/10/2016
Oct-16	No discharge				16/11/2016
ID No. 25: 02/11/2016	7.1*	4.9*	<5*		16/11/2016
Dec-16	No discharge				13/01/2016
Jan-17	No discharge				16/02/2017
Feb-17	No discharge				15/03/2017
Mar-17	No discharge				8/05/2017
Apr-17	No discharge				8/05/2017
May-17	No discharge				14/06/2017
Jun-17	No discharge				10/07/2017
Jul-17	No discharge				29/08/2017
Aug-17	No discharge				29/08/2017
ID No. 25: 05/09/2017**	7.1	4.6	<5		8/11/2017
Oct-17	No discharge				8/11/2017
Nov-17	No discharge				8/02/2018
ID No. 25: 07/12/2017**	7.1	5.5	<5		17/08/2018
ID No. 25: 12/12/2017**	7.1	6.8	9		8/02/2018
Jan-18	No discharge			NA	8/02/2018
Feb-18	No discharge			NA	16/03/2018
Mar-18	No discharge			NA	9/05/2018
Apr-18	No discharge			NA	9/05/2018
May-18	No discharge			NA	19/06/2018
Jun-18	No discharge			NA	15/08/2018

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
Clyde Terminal: Durham Street, Camellia NSW					
Environment Protection Licence (EPL) 570					
EPA ID No.25 – Flexible discharge outlet					
Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Data obtained Date	Publishing Date
Licence Limit	6.0-9.0	100	50		
Units of Measure		mg/L	mg/L		
Frequency as per EPL	<24 hrs prior to discharge	<24 hrs prior to discharge	<24 hrs prior to discharge		
Jul-18	No discharge			NA	15/08/2018
Aug-18	No discharge			NA	5/11/2018
Sep-18	No discharge			NA	5/11/2018
Oct-18	No discharge			NA	5/11/2018
Nov-18	No discharge			NA	31/12/2018
Dec-18	No discharge			NA	31/12/2018
Jan-19	No discharge			NA	25/03/2019
Feb-19	No discharge			NA	25/03/2019
Mar-19	No discharge			NA	11/06/2019
Apr-19	No discharge			NA	11/06/2019
May-19	No discharge			NA	11/06/2019
Jun-19	No discharge			NA	19/08/2019
Jul-19	No discharge			NA	19/08/2019
Aug-19	No discharge			NA	23/10/2019
Sep-19	No discharge			NA	23/10/2019
Oct-19	No discharge			NA	11/12/2019
Nov-19	No discharge			NA	11/12/2019
Dec-19	No discharge			NA	6/02/2020
Jan-20	No discharge			NA	6/02/2020
Feb-20	No discharge			NA	13/03/2020
Mar-20	No discharge			NA	15/05/2020
Apr-20	No discharge			NA	15/05/2020
May-20	No discharge			NA	17/07/2020
Jun-20	No discharge			NA	17/07/2020
Jul-20	No discharge			NA	18/08/2020
Aug-20	No discharge			NA	11/09/2020
Sep-20	No discharge			NA	19/10/2020
Oct-20	No discharge			NA	16/11/2020

NOTE: * top, middle and bottom samples taken, middle sample used as “grab”.

** Sample date 5/9/17 - Volume discharged was 3ML per day on 6th, 7th & 8th Sept (total 9ML)

** Sample date 7/12/17 - Volume discharged was 3.24ML per day on 9th & 10th Dec (total 6.483ML)

This document may contain information, data, opinions or predictions from Viva Energy or sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information, data, opinions or predictions (whether for commercial purposes or otherwise) does so at their own risk. Viva Energy (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information, data, opinions or predictions, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.

Licensee: Viva Energy Australia Pty Ltd					
Clyde Terminal: Durham Street, Camellia NSW					
Environment Protection Licence (EPL) 570					
EPA ID No.25 – Flexible discharge outlet					
Pollutant	pH	Total Organic Carbon	Total Suspended Solids	Data obtained Date	Publishing Date
Licence Limit	6.0-9.0	100	50		
Units of Measure		mg/L	mg/L		
Frequency as per EPL	<24 hrs prior to discharge	<24 hrs prior to discharge	<24 hrs prior to discharge		

** Sample date 12/12/17 - Volume discharged was 5ML per day on 19th, 20th & 21st Dec (total 15ML)